

Missouri Department of Transportation

Northeast District – Macon Regional Office General Services Division – Procurement Department www.modot.org 1-888-ASK-MoDOT 26826 U.S. Highway 63 Macon, MO 63552 (660)-385-8245 – phone (573)-526-3169 – fax

ADDENDUM 001 REQUEST FOR BID (RFB) NUMBER: NE13-20B-R2

September 24, 2012

The following notes are provided to all potential vendors as notification of items of general information, answers to questions received to date, and changes to the scope of work that have been authorized since the original posting of the referenced RFB:

- 1. MoDOT is increasing the number of days allowed from 18 days to 25 days. The 25 days will begin when the bridge is closed and will end when the concrete is fully cured and the bridge is reopened to traffic.
- **2. Will our annual MODOT bid bond be sufficient for this job?** No. The annual bid bonds maintained by Design and Construction are not applicable and cannot be used to bond bids issued by General Services, due to varying guidelines and statutory requirements applicable to each division of MoDOT.
- **3.** The following are approved suppliers of the strip seal materials: Carter-Waters (Kansas City, MO); D.S. Brown Co. (North Baltimore, OH); Hennegan and Associates (Lemont, IL); Iron Works, a division of Progressive Contractors Inc. (Becker, MN); Watson Bowman Acme Corp. (Amherst, NY). I don't have any additional contact information for these companies.
- **4.** There is a 2" asphalt overlay over the entire bridge. How were the locations determined? The locations were determined by measuring the underside of the deck.
- **5. Will it be ok for the broken and deteriorated concrete to fall in the river?** No. Please refer to the Job Special Provisions.
- 6. Is a 7 day wet cure going to be required on the deck portions of the bridge being replaced? Yes.
- **7.** Has any thought been put in a complete overhang replacement? Yes, this was considered and deemed un-economical.
- 8. Is the 18 day requirement just for complete closure or can we perform some work under a flagging operation prior to the 18 day clock starting? No work will be allowed under a flagging operation.

All other requirements and details of the RFB remain unchanged. The response deadline remains as due no later than 1:00 PM, Friday, September 28, 2012. Sealed bid responses should be delivered to the MoDOT Northeast District Procurement Office in Macon before the required response deadline. Responses by fax or email cannot be accepted.

Bill

William D. "Bill" Noyes, CPPO, CPPB Senior Procurement Agent

